Mission:

To protect, promote & improve the health of all people in Florida through integrated state, county & community efforts.



Ron DeSantis
Governor

Joseph A. Ladapo, MD, PhD State Surgeon General

Vision: To be the Healthiest State in the Nation

October 3, 2023

Laurel Road Development, LLC. Attn: John Peshkin 7350 Point of Rocks Road Sarasota, FL 34232

RE: Mirasol Town Center

Final Certification; Permit #: 0124807-203-DSGP

PWS: City of Venice Utilities (6581901)

Dear Mr. Peshkin:

This acknowledges receipt of a certified request received by Department of Health for a final letter of release for installed potable water mains and associated appurtenances per certified record drawings as part of Mirasol Town Center in City of Venice Utilities service area.

Your engineer of record has certified that the subject facilities have been completed in accordance with the approved plans and specifications. These facilities were cleared bacteriologically in accordance with Rule 62-555.345 Florida Administrative Code. Bacteriological samples and pressure testing results are acceptable and meet DOH and DEP requirements. Deviation of adjusting watermain ±9-LF to south to shift further from proposed building on Lot 13 from the permitted plan is also approved.

Changes in applicable laws and regulations with affect to operating procedures and/or quality standards must be complied with. In addition, we wish to call your attention to the requirements that no sanitary hazards, regardless of how slight, shall be placed within 100 feet of public water supply well and under certain circumstances, this distance can be increased.

Based on this information, we are issuing this letter of release to place into service the installed PWS components to provide potable water and fire protection service for Mirasol Town Center.

Please contact me at 941-228-7344 if you have additional questions.

Sincerely,

Paul B. Penumudi. P.E.

OFFICE OF ENVIRONMENTAL HEALTH

PBP: J:/EH/PWS

c: City of Venice Utilities Department, Attn: Javier Vargas AM Engineering Inc., Attn: D. Shawn Leins, P.E.



PHONE: 941/861-6133 • FAX: 941/526-1535