



Building Health Check is a Division of Pure Air Control Services, Inc.

Building Health Check Report
Prepared for

Darryl Blair,
Energy Management Facilites Planning
Sarasota County Government
1001 Sarasota Center Blvd
Sarasota, FL 34240
941-861-0868

Date of Study: December 23, 2015
Date of Report: January 6, 2016

Report # 3929-19392

Sarasota County Government
Venice Library
300 S. Nokomis Ave.
Venice, FL 34285

Prepared By

Aaron Hallam
Building Scientist

Indoor Environmental Diagnostic & Remediation Specialist

HVAC FL License # CAC057992

1(727) 572-4550

1(800) 422-7873

Copyright 2015 Pure Air Control Services, Inc.

January 6, 2016



Darryl Blair,
Energy Management Facilities Planning
Sarasota County Government
1001 Sarasota Center Blvd
Sarasota, FL 34240



**Re: Venice Public Library
Building Health Check Report 3929-19392**

Darryl Blair,

It is Pure Air Control Services, Inc. (Pure Air) privilege to submit this report that describes the Building Health Check evaluation undertaken at the Venice Library, 300 S. Nokomis Ave., Venice, FL for your review. Field assessments were completed on December 23, 2015 to address concerns related to the quality of the indoor air.



*Publisher of the
IEQ Review*

Thank you for providing Pure Air this opportunity to assist you with your indoor air quality concerns. If you should have any questions regarding this report provided, please call me at 1-800-422-7873, ext. 201.



Respectfully Submitted,

PURE AIR CONTROL SERVICES, INC.

Aaron Hallam

HVAC FL License
#CACO57992

Aaron Hallam
Building Scientist



Member



CONTENTS

| | |
|--|-----------|
| INTRODUCTION | 1 |
| BACKGROUND | 1 |
| SCOPE OF WORK | 1 |
| ENVIRONMENTAL SUMMARY REPORT | 2 |
| CONCLUSIONS | 5 |
| RECOMMENDATIONS | 7 |
| PHOTOGRAPHS | 8 |
| LABORATORY RESULTS | 15 |
| METHODS | 59 |
| GUIDELINES FOR INDOOR AIR QUALITY | 61 |
| INDOOR AIR QUALITY CONSIDERATIONS | 65 |
| DISCLAIMERS | 69 |



INTRODUCTION

This report describes the Building Health Check evaluation undertaken at Venice Library, 300 S. Nokomis Ave., Venice, FL. The assessment was completed on December 23, 2015 at the request of Mr. Darryl Blair of Sarasota County Government to address occupant concerns related to the quality of the indoor air.

BACKGROUND

Over the years the Venice Library has had numerous water intrusion events believed to be related to moisture infiltrating through the slab and/or at grade from water accumulation outside the building. Pure Air, an independent firm was called to perform a due diligence study on behalf of Sarasota County Government to ascertain the general health and quality of the indoor air. They are in the process of relocating the contents and staff with the hopes of being done in next 4-5 months. The library will stay open until that time. The results for such due diligence assessment are the subject of this report.

SCOPE OF WORK

The assays performed in this study included:

- Cultures for the assessment of viable bacterial and fungal concentrations suspended in the air.
- Spore Traps to determine the concentrations of fungal structures suspended in the air.
- Surface Tape Preparations to assess the distribution of fungal structures settled on the environment.
- Measurements of temperature and relative humidity for the assessment of comfort and conditions that might support microbial proliferation and chemical interactions.
- Measurements of carbon dioxide as a surrogate measure for ventilation adequacy.
- Particle counting of respirable-size as an indicator of air filtration efficiency and/or unusual dust levels.
- Infrared scan and direct contact moisture measurements for the detection of damp building materials.
- The assessment also included a visual inspection of the air handler and the air distribution system to address any potential sanitary conditions that may need attention.



ENVIRONMENTAL SUMMARY REPORT

Environmental assays were performed in 10 representative zones throughout the library. When pertinent, outside air samples were collected for comparative and control purposes. These environmental samples were submitted to the Environmental Diagnostics Laboratory (EDL), for analysis. The results derived from each assay were compared against the corresponding Guidelines to determine acceptability and were tabulated on the following page. Please note that the figures highlighted in yellow (if any) contain values moderately outside the recommended level and are treated as a transition gradient from a normal condition to abnormal or vice versa. Figures highlighted in red (if any) indicate with certainty that an abnormal or detrimental condition exists.



Air Quality

| Matrix | Aspect | Unit | Guideline* | Ref. | Workroom Area | Large Print Area | Information Area | Reading Area | Genealogy Area | Youth Program Area | Outside Air |
|-------------|---------------------|--------------------|-------------------|------|---------------|------------------|------------------|--------------|----------------|--------------------|-------------|
| Cultures | Bacteria | CFU/m ³ | ≤175 or 1/3 OA | 3 | 12 | 36 | 36 | 95 | 12 | 36 | 143 |
| | Fungi | CFU/m ³ | ≤350 or 1/3 OA | 3 | 24 | 60 | 24 | BDL | 36 | 60 | 631 |
| Spore Traps | Opaque Particles | cts/m ³ | ≤35,000 or 1/3 OA | 3 | 17,500 | 51,400 | 6,520 | 1,070 | 7,930 | 22,800 | 4,810 |
| | Skin Cell Fragments | cts/m ³ | ≤7,500 | 3 | 222 | 1,780 | 400 | 66 | 911 | 1,040 | 44 |
| | Insect Biotritrus | cts/m ³ | ≤200 or 1/3 OA | 3 | BDL | BDL | BDL | BDL | BDL | BDL | BDL |
| | Fibers | cts/m ³ | ≤500 | 3 | BDL | BDL | BDL | BDL | 22 | 22 | BDL |
| | Fiberglass fibers | cts/m ³ | ≤5 | 3 | BDL | BDL | BDL | BDL | BDL | 22 | BDL |
| | Pollen | cts/m ³ | ≤15 or 1/3 OA | 3 | BDL | BDL | BDL | BDL | BDL | BDL | BDL |
| | Fungal Elements | cts/m ³ | ≤1000 or 1/3 OA | 3 | BDL | 110 | 66 | 22 | BDL | BDL | 1,060 |
| | Other | cts/m ³ | ≤6000 or 1/3 OA | 3 | 22,600 | 50,000 | 7,900 | | 6,400 | 5,560 | |
| | Respirable size | p/l | ≤25,000 or 1/3 OA | 3 | 9,856 | 8,867 | 9,581 | 9,299 | 9,342 | 10,404 | 50,115 |
| | Temperature | °F | 72 to 78 | 1 | 73.4 | 75 | 73.4 | 74.1 | 74.6 | 71.5 | 74.8 |
| Comfort | Relative Humidity | % | 30 to 60 | 1 | 65.8 | 67 | 65.9 | 68.5 | 66.9 | 75.1 | 90.4 |
| | Carbon Dioxide | ppm | 700+OA | 2 | 415 | 403 | 361 | 343 | 345 | 365 | 333 |

Settled Aerosols in the Occupiable Space

| Matrix | Aspect | Unit | Guideline* | Ref. | Top of Cabinet | Top of Bookshelf | Bookshelf | Newspaper Stand | Red Book 3rd Edition | N/A | NA |
|-----------|---------------------|---------------------|------------|------|----------------|------------------|-----------|-----------------|----------------------|-----|----|
| Tape Prep | Opaque Particles | cts/cm ² | ≤3000 | 3 | 3,930 | 7,050 | | 421 | 2,100 | | |
| | Skin Cell Fragments | cts/cm ² | ≤600 | 3 | 1,380 | 687 | | 64 | 673 | | |
| | Insect Biotritrus | cts/cm ² | ≤4 | 3 | BDL | BDL | | BDL | BDL | | |
| | Fibers | cts/cm ² | ≤120 | 3 | 216 | 176 | 388 | 84 | 168 | | |
| | Fiberglass Fibers | cts/cm ² | ≤4 | 3 | 4 | 4 | 4 | 4 | 16 | | |
| | Pollen | cts/cm ² | ≤4 | 3 | 8 | 8 | | BDL | BDL | | |
| | Fungal Elements | cts/cm ² | ≤50 | 3 | 24 | 24 | | BDL | 8 | | |
| | Other | cts/cm ² | ≤650 | 3 | 1,390 | 928 | | 220 | 280 | | |

Foot Notes

| Units | Reference | Notes |
|--|------------------------------------|------------------------------|
| CFU/m ³ = Colony Forming Units per Cubic Meter of Air | 1. ASHRAE 55 - 2010 | BDL = Below Detectable Limit |
| cts/m ³ = Counts per Cubic Meter of Air | 2. ASHRAE 62.1 - 2013 | OA = Outside Air |
| cts/cm ² = Counts per square centimeter | 3. Pure Air Control Services, Inc. | Red = Abnormal/Detrimental |
| p/l = Particles per liter of Air | 4. Molhave 1990 | Yellow = Moderately elevated |

NA = Not Applicable
* = See Guidelines Section



Air Quality

| Matrix | Aspect | Unit | Guideline* | Ref. | Juvenile Non Fiction | Teen & Youth Area | Book Store | Lobby Area | Meeting Room | Outside Air |
|-----------------|---------------------|--------------------|-------------------|------|----------------------|-------------------|------------|------------|--------------|-------------|
| Cultures | Bacteria | CFU/m ³ | ≤175 or 1/3 OA | 3 | 83 | | 48 | 71 | 24 | 143 |
| | Fungi | CFU/m ³ | ≤350 or 1/3 OA | 3 | 36 | | 24 | 36 | BDL | 631 |
| Spore Traps | Opaque Particles | cts/m ³ | ≤35,000 or 1/3 OA | 3 | 10,700 | | 18,100 | 58,900 | 13,200 | 4,810 |
| | Skin Cell Fragments | cts/m ³ | ≤7,500 | 3 | 667 | | 933 | 267 | 178 | 44 |
| | Insect Biodetritus | cts/m ³ | ≤200 or 1/3 OA | 3 | BDL | | BDL | BDL | BDL | BDL |
| | Fibers | cts/m ³ | ≤500 | 3 | 44 | | 22 | 22 | BDL | BDL |
| Fungal Elements | Fiberglass fibers | cts/m ³ | ≤5 | 3 | BDL | | BDL | 22 | BDL | BDL |
| | Pollen | cts/m ³ | ≤15 or 1/3 OA | 3 | BDL | | BDL | BDL | BDL | BDL |
| | Other | cts/m ³ | ≤1000 or 1/3 OA | 3 | 44 | | 88 | 88 | 10,500 | 1,060 |
| Particle | Respirable size | p/l | ≤6000 or 1/3 OA | 3 | 7,650 | | 15,800 | 48,000 | 20,900 | |
| | Temperature | °F | 72 to 78 | 1 | 74 | | 6,996 | 10,485 | 11,665 | 50,115 |
| Comfort | Relative Humidity | % | 30 to 60 | 1 | 69.5 | | 64 | 65.9 | 74.7 | 74.8 |
| | Carbon Dioxide | ppm | 700+OA | 2 | 358 | | 420 | 345 | 336 | 333 |

Settled Aerosols in the Occupiable Space

| Matrix | Aspect | Unit | Guideline* | Ref. | Bookshelf | Desk Chair | Bookshelf | Bookshelf | NA | NA |
|------------|---------------------|---------------------|------------|------|-----------|------------|-----------|-----------|----|----|
| Tape Prep | Opaque Particles | cts/cm ² | ≤3000 | 3 | 558 | 2,010 | 15,100 | 11,700 | | |
| | Skin Cell Fragments | cts/cm ² | ≤600 | 3 | 76 | 1,160 | 7,100 | 2,650 | | |
| | Insect Biodetritus | cts/cm ² | ≤4 | 3 | BDL | BDL | BDL | BDL | | |
| Foot Notes | Fibers | cts/cm ² | ≤120 | 3 | 16 | 416 | 332 | 660 | | |
| | Fiberglass Fibers | cts/cm ² | ≤4 | 3 | BDL | 12 | 8 | 8 | | |
| | Pollen | cts/cm ² | ≤4 | 3 | BDL | 8 | 44 | 60 | | |
| | Fungal Elements | cts/cm ² | ≤50 | 3 | BDL | 320 | 20 | 60 | | |
| Other | cts/cm ² | ≤650 | 3 | 284 | 1,170 | 5,580 | 4,000 | | | |

Foot Notes

| Units | Reference | Notes |
|--|------------------------------------|------------------------------|
| CFU/m ³ = Colony Forming Units per Cubic Meter of Air | 1. ASHRAE 55 - 2010 | BDL = Below Detectable Limit |
| cts/m ³ = Counts per Cubic Meter of Air | 2. ASHRAE 62.1 - 2013 | OA = Outside Air |
| cts/cm ² = Counts per square centimeter | 3. Pure Air Control Services, Inc. | Red = Abnormal/Detrimental |
| p/l = Particles per liter of Air | 4. Mollhave 1990 | Yellow = Moderately elevated |



CONCLUSIONS

Based on the results derived from the environmental samples collected no imminent health concerns were collected. However, large areas with moisture intrusion underneath the carpets and dusty environmental conditions exist throughout the library that some hypersensitive individuals may not find it suitable.

Air samples collected using the culture method for the assessment of microbial concentrations suspended in the air revealed levels of bacteria well within the recommended guideline in all of the representative zones evaluated. The levels of fungi suspended in the air were well within the recommended guidelines in all of the representative zones evaluated and raised no significant health concerns.

Air samples collected with the spore trap method (Air-O-Cell Cassettes) for the assessment of fungal structures suspended in the air revealed levels well within the recommended guideline in all zones assessed in the library. No concerns were raised by this assay method.

Surface tape preparations were collected to assess the settled distribution of fungal structures and other allergens. The analytical results for the surface tape preparations collected from all representative areas tested revealed markedly dusty conditions; however, the fungal content (settlement) was elevated only in one (1) of the nine (9) representative zones sampled.

Dust particles whose overall diameter ranges from 0.3 to 5.0 microns are recognized as respirable-size particles. Respirable-size particles are generated by a broad variety of processes and activities and there are increasingly more studies linking associations between the concentrations of particles and health effects. In this case, the respirable-size particle concentrations detected in all of the zones evaluated were well within the recommended levels, which raised no concerns at this time.

The ventilation requirement for most buildings is supplied by the HVAC system and/or by infiltration of the outside air. Carbon dioxide (CO₂) concentrations are used as surrogate measure to roughly assess the adequacy of the ventilation system. The results for the CO₂ measurements made at the time of the field evaluation were well within the recommended guideline. No concerns were raised by this assay method.

Temperature and relative humidity measurements of the ambient air were used to assess comfort, as well as an environmental factor that may increase the prevalence of indoor air quality problems (e.g. microbial activity, indoor allergens, viral infections, allergic rhinitis, asthma, ozone production, odors, etc.). There is no specific set of



CONCLUSIONS (continued)

recommended values for temperature and relative humidity; however, comfort depends principally on these two factors combined. For indoor air quality and health reasons it is recommended that the relative humidity be maintained in the range of 30 to 60%. With some exceptions the temperature in the cooling mode needs to be maintained at a set point in the range of 73 to 79 °F and between 68 to 74 °F during the winter (see Standard Effective Temperature and ASHRAE Comfort Zone illustration provided for details). In this assessment, the relative humidity was well above the recommended levels for comfort and the control of allergens production. The temperature readings were within comfort ranges throughout the library.

Air handlers and duct systems that contain excessive dust, debris, and moisture are places where bacteria and fungi may proliferate and release odors and potentially other contaminants into the air stream. In this case, the air handler located in the Meeting Room, AHU-2 was inspected to assess the hygienic condition. In general, the air handlers are relatively new, but are beginning to show dust impactions on the cooling coils and blower wheels which appears to be a deficiency with the air filtration. Also, air handler 2 was found with the insulation liner delaminated from the access panel which may release fiberglass fibers into the air stream.



RECOMMENDATIONS

No new recommendations to add as everything has been covered by Pure Air's prior reports, those recommendations were designed to resolve issues described in the two (2) previous reports. No prioritization was implied by this listing, however, it was anticipated all items discussed would be addressed.

General

- ❖ Set the thermostats (and any other relevant controls) to maintain the temperature and relative humidity within the ASHRAE recommended levels of 73 to 79 °F (summer) 68 to 74 °F (winter). Relative humidity should be maintained in the range of 30 and 60%.