Mission:

To protect, promote & improve the health of all people in Florida through integrated state, county & community efforts.

Ron DeSantis Governor

Joseph A. Ladapo, MD, PhD State Surgeon General

December 20, 2022

Border Road Investments LLC. Attn: David Goben 5800 Lakewood Ranch Blvd. Sarasota. FL 34240

RE: Vistera of Venice Partial Certification

Permit #: 0124807-230-DSGP

PWS: City of Venice Utilities (6581901)

Dear Mr. Goben:

This acknowledges receipt of a certified request received by Department of Health for a partial letter of release for installed 210-LF of 8" PVC Watermain, 1,520-LF of 12" PVC Watermain public water system (PWS) components and associated appurtenances per certified record drawings as part of Vistera of Venice project in City of Venice Utilities service area.

Your engineer of record has certified that the subject facilities have been completed in accordance with the approved plans and specifications. These facilities were cleared bacteriologically in accordance with Rule 62-555.345 Florida Administrative Code. Bacteriological samples and pressure testing results are acceptable and meet DOH and DEP requirements. There are no deviations from the permitted plans.

Changes in applicable laws and regulations with affect to operating procedures and/or quality standards must be complied with. In addition, we wish to call your attention to the requirements that no sanitary hazards, regardless of how slight, shall be placed within 100 feet of public water supply well and under certain circumstances, this distance can be increased.

Based on this information, we are issuing this letter of release to place into service the installed PWS components to provide potable water and fire protection service for Vistera of Venice project.

Please contact me at 941-228-7344 if you have additional questions.

Sincerely.

Paul B. Penumudi, P.E.

OFFICE OF ENVIRONMENTAL HEALTH

PBP: J:/EH/PWS

c: AM Engineering, Inc., Attn: Bobbi Claybrooke, P.E. City of Venice Utilities, Attn: Javier A. Vargas

