



February 23, 2021

David Verinder, CEO
Sarasota Memorial Hospital District
1700 South Tamiami Trail
Sarasota, Florida 34239

Subject: **Sarasota Memorial Hospital-Venice** Wastewater Collection System, Permit No. CS58-381690; Request for **Partial Approval** to Place a Domestic Wastewater Collection/Transmission System into Operation

Dear Mr. Verinder:

Air and Water Quality has received the Request for Approval to Place a Domestic Wastewater Collection/Transmission System into Operation for the completed portion of the subject project authorized by Permit No. CS58-381690, dated December 10, 2019 with connection to the City of Venice Wastewater Treatment Facility, FL0041441. The permit is hereby modified as follows:

The following portions of the system are approved for service: 3,011 linear feet of 8-inch diameter gravity sewer, 1,769 linear feet of 10-inch gravity sewer, 2,056 linear feet of 4-inch force main, 24 manholes, and 1 lift station.

Air and Water Quality has no objection to placing this portion of the system into use.

Please be aware that approval of individual connections to a completed collection/transmission system must be obtained from the permittee of the treatment/disposal system.

This letter constitutes modification of the subject permit and, therefore shall be appended to it. All future correspondence should reference the permit number CS58-381690.

Please contact Chris Murray, Environmental Specialist, Air and Water Quality at 941-725-5040 if you have any questions.

Sincerely,

John T. Hickey, P.E.
Professional Engineer #49412
Manager, Air and Water Quality

cc: Melanie D. Smith, P.E., Engineer of Record, Stantec Consulting Services (email)
Javier Vargas, Director of Utilities, City of Venice (email)
Michael Mehan, P.E., Manager, Public Utilities (email)
Veronica Ford, Permitting Coordinator, Public Utilities (email)

C21CC.112