To protect, promote & improve the health of all people in Florida through integrated state, county & community efforts.

Ron DeSantis Governor

Scott A. Rivkees, M.D. State Surgeon General

April 27, 2020

Neal Communities of Southwest Florida, LLC Mr. James Schier 5800 Lakewood Ranch Boulevard North Sarasota, FL 34240

RE: Aria

WD: 1901-18-007; Partial Certification

Permit #: 0124807-182 PWS: City of Venice Utilities

Dear Mr. Schier:

This acknowledges receipt of a certified request for a partial letter of release for the portion of water main construction that is for approximately 1,737-LF of 8-inch PVC water main. Specifically defined as water main from Lots 1 through 10 and Lots 24 through 43.

Your engineer of record has certified that the subject facilities have been completed in accordance to the approved plans and specifications. These facilities were cleared bacteriologically in accordance with Rule 62-555.345 Florida Administrative Code. Bacteriological samples and pressure testing results are acceptable.

Changes in applicable laws and regulations with affect operating procedures and/or quality standards must be complied with. In addition, we wish to call your attention to the requirements that no sanitary hazards, regardless of how slight, shall be placed within 100 feet of public water supply well and under certain circumstances, this distance can be increased.

Should you have any questions, please contact me at 228-7344.

Sincerely,

Paul B. Penumudi, P.E.

OFFICE OF ENVIRONMENTAL HEALTH

PBP:mr

cc: Javier Vargas/City of Venice Utilities Director

Travis J. Fledderman, P.E./ Stantec Consulting Services, Inc.

FloridaHealth.gov