

Mid Florida Diesel, Inc.

MV-30429

PROPOSAL

2215 Highway 60 East
Bartow, FL. 33830
Ph 863.519.0107 Fx 863.519.0109
Midfloridadiesel.com

4529

Date

1/23/2019

DO NOT PAY
ESTIMATE ONLY

BILL TO:

City of Venice
401 W. Venice Ave
Venice, FL. 34285
Water Production Utilities/Water
Production Dept.

CITY OF VENICE
WATER DEPT
ATTN: DARREN ADDY

WO#		UNIT#	ENGINE MAKE/MOD	UNIT MAKE/MODEL	ARR/SPEC
		WP 250KW Cummins/Boos...	Cummins NT 855 G5	Cummins NT 855-65	1002847
PO#	TERMS	UNIT SER#	ENGINE SER/VIN	KW	HRS/MILES
	1% 10 Net 30	284154	11568463	250	467
PART#	QTY	DESCRIPTION		RATE	AMOUNT
Onsite Labor	1	REMOVE EXISTING 250KW CUMMINS AND REPLACE WITH NEW 250KW BLUE STAR GENERATOR		12,500.00	12,500.00
Rental Equipment	1	TELEHANDLER RENTAL - 1 WEEK		2,500.00	2,500.00
SUPPLIES - FIE...	1	SUPPLIES - FIELD		4,000.00	4,000.00
		*****EXCEPTIONS*****			
		-GENERATOR BACKUP POWER UNAVAILABLE FOR 1 WEEK (UNLESS RENTAL GENERATOR IS REQUIRED)			
		-LOUVER WILL BE REMOVED AND OPENING WILL BE EXPOSED FOR 1 WEEK			
		-EXISTING MUFFLER, EXHAUST PIPING AND THIMBLE TO BE REUSED			
		-CITY WILL SUPPLY AND INSTALL NEW ELECTRICAL CONNECTIONS FOR BLOCK HEATER AND BATTERY CHARGER LOCATED ON THE NEW GENERATOR - 2 SEPERATE CIRCUITS WILL BE REQUIRED			
SIGNATURE:			DATE:	Subtotal	\$19,000.00
				Sales Tax (7.0%)	\$0.00
				Total	\$19,000.00

NC/No Charge RD/reduced U/Used R/Rebuilt RC/Reconditioned

NC/No Charge RD/Reduced U/Used R/Rebuilt RC/Reconditioned

____ month/____ mile warranty on parts & labor unless otherwise specified

Labor Rate Based On: Flat Rate ____ Hrly Rate ____ Both ____ Save parts for inspection or return Y or N.

*FS 403.718 mandates a \$1.50 fee for any new or reman battery sold in Florida.


**Guarantee/Warranty, if applicable.

***Charge represents costs & profits to the motor vehicle repair facility for miso. shop supplies or waste disposal.

I authorize the above repair work to be done along w/ the necessary materials & operation of vehicle for testing or delivery. It is understood that Mid Florida Diesel, Inc., and or employees will not be held responsible for loss or damage to the above described vehicle, or articles left therein, in case of fire, theft, or nature.

NOTE: THIS IS JUST AN ESTIMATED COST - ADDITIONAL PARTS AND LABOR MAY BE NEEDED UPON TEAR DOWN OF UNIT.

MID FLORIDA DIESEL



2215 HIGHWAY 60 EAST
BARTOW, FL. 33830
(863) 519-0107 FAX (863) 519-0109
WWW.MIDFLORIDADIESEL.COM

January 22, 2019

PROPOSAL

For

250KW Diesel Generator

Florida Sheriff Association Bid FSA 18-VEH16.0 Specification #76

City of Venice
200 North Warfield Ave
Venice, FL 34285

ATTN: Darren Addy

Mid Florida Diesel submits the following proposal for the project: **Booster station**

Blue Star Power Systems MODEL: (Qty. - 1) JD250-02

(Quote # 01222019-JA)

GENERATOR: 250 kW, 312 kVA
VOLTAGE: 480 volt Three-Phase
ENGINE: John Deere 6090HF484, 60 Hz Diesel, 1800 RPM

Standard Features Included:

Microprocessor based, digital readout control system.
Engine vitals monitored by LCD display: Oil pressure, Running time, Engine temperature, Safety shutdowns (HWT, OC, OS, OP, LWL), Battery voltage, Generator AC voltage, AC amperage, Frequency.
Additional Features: Oil drain extension, Vibration isolation pads, Water heater, Fuel solenoid valve.

Selected Model Features Included:

Isochronous Governor + / - .25%
UL2200
EPA Tier II Certified
130 Degree Temperature Rise

CONTROL PANEL:

DGC-2020 Control Panel (Expanded)

Blue Star DGC-2020 Microprocessor Based Gen-Set Controller
Mounted Facing Left from Generator End (Unless Specified Otherwise)
Standard Features: Low Oil Pressure, High Coolant Temp, Overspeed, Overcrank Shutdowns
Emergency Stop Pushbutton, Audible Alarm Buzzer with Silencing Switch
Optional Features Include: Generator Protection (Undervoltage, Overvoltage, Underfrequency, Overfrequency, Overcurrent)
Included Accessories

ENCLOSURE:

Weather Proof Enclosure--- Level II Steel Enclosure

Weather Proof Enclosure- Made with 14 Gauge steel with louvered rear opening for air intake and punched side air openings for air intake and silencer is mounted inside enclosure with exhaust exiting through front sound compartment. Pitched roof for increased structural integrity and improved watershed. Lockable handles keyed alike with hinged doors

Accessories:

Sound Attenuation Foam 1.5"
150 mph Wind Load Rated

COOLING SYSTEM:

Unit Mounted Radiator

Accessories:

Low Coolant Level Shutdown

CIRCUIT BREAKERS:

400 A BREAKER – 600v Thermal Magnetic 80% rated
Mounted and Wired in a NEMA 1 Enclosure (Qty: (1 per gen)
Circuit Breaker - UL listed and CSA certified.

Accessories:

BATTERY:

Lead Acid Battery

BLOCK HEATER:

Standard 2500W 240VAC@ 20 F w/Isolation valves

VIBRATION ISOLATION:

Vibration Pads Isolator

BATTERY CHARGER:

(12 Volt, 6 Amp)

Included Accessories:

SUB BASE TANK:

Sub Base Fuel Tank Steel (with Stub Up) (540 Gallons Capacity-24hrs run time)

Accessories:

UL 142 Approved

Double Wall

Emergency Pressure Relief Vent Cap Set (1/2 PSI) - 2" (1)

1.5" Normal Vent Cap

MUFFLER:

Critical Grade Muffler –

Accessories:

Rain Cap

MISCELLANEOUS:

Certified Factory Test

Manual – One (1) Instruction Manuals

2 Yr/2000 Hr Standby Limited Warranty

Test Acceptance Run by Factory Trained Representative (Start Up)

NOTES:

1. This proposal is our interpretation of your requirement and includes only the items listed. Should there be other requirements or specifications, we will requote accordingly.
2. Units are shipped wet to include lube oil and a 50/50 water and anti-freeze mix unless otherwise noted in this quotation.
3. Startup performed upon notification of completed installation by installing contractor.
4. CANCELLATION: Shall be subject to applicable fees but no less than 20% of the purchase price
6. EXCLUSIONS: Installation of any kind, Offloading of Generator, Placement of Generator on Pad, Fuel, Springs Isolator, Tank, Piping, and Insulation. We have not seen specs.
7. Start Up included in price

8. Freight included in the price. Off-loading of generator by others
9. Terms: Net 30 Day-- No retain age without written pre-accepted agreement.

Proposal Summary:	FSA Spec #076Standard Blue Star JD125-02 Bid:	\$29,800.00
	FSA Add Option-Upgrade to a 250KW- Specification #076 (Order Code-JD250-02):	\$24,400.00
	Sub-Total:	\$54,200.00*

*ADDER: Specification #076 - Permanent Magnet (Order Code-PMG):	\$990.00
Sub-Total:	\$55,190.00

-Remove 24 hr. 540 Gallon UL 142 Diesel Tank:	-\$3,800.00)
-Remove Level II Steel Enclosure:	-\$5,045.00)
Sub-Total:	-\$8,845.00)

Total Price:	\$46,345.00
	(Tax Not Included)

Note: * See attached FSA Bid and Spec sheets

Quoted prices do not include Federal, State or Local taxes which may be applicable. Quoted prices include normal testing, packaging and instructional literature. Special testing, packaging, additional instructional literature, parts, provisioning lists or prints are not included, and prices will be quoted separately.

Quotation Firm for 30 Day(s)
Delivery Notes: 12-14 Weeks

BY: Joe Antonini
Joe Antonini
Mid Florida Diesel, Inc.