

Scott A. Rivkees, M.D. State Surgeon General

Vision: To be the Healthiest State in the Nation

March 31, 2020

Neal Communities of Southwest Florida, LLC Attn: James Schier, Vice President 5800 Lakewood Ranch Boulevard North Sarasota, FL 34240

RE: Aria -Phase 2 WD: 1901-18-007; Partial Certification Permit #: 0124807-182 PWS: City of Venice Utilities

Dear Mr. Schier:

This acknowledges receipt of a certified request for a partial letter of release for the portion of water main construction that is for portion of 2,267-LF of 8-inch PVC water main. Specifically partial approval is for potable water mains serving lots 116 through 174.

Your engineer of record has certified that the subject facilities have been completed in accordance to the approved plans and specifications. These facilities were cleared bacteriologically in accordance with Rule 62-555.345 Florida Administrative Code with submission of satisfactory bacteriological samples collected on 2/5/20 and 2/6/20. Bacteriological and pressure testing results meet DOH and DEP requirements.

Changes in applicable laws and regulations with affect operating procedures and/or quality standards must be complied with. In addition, we wish to call your attention to the requirements that no sanitary hazards, regardless of how slight, shall be placed within 100 feet of public water supply well and under certain circumstances, this distance can be increased.

Should you have any questions, please contact me at 228-7344.

Sincerely,

Paul B. Penumudi, P.E. OFFICE OF ENVIRONMENTAL HEALTH

PBP:mr

cc: Javier Vargas, /City of Venice, Utilities Director Melanie D. Smith, PE, LEED GA/Stantec Consulting Services Inc.

Florida Department of Health in Sarasota County • Office of Environmental Health 1001 Sarasota Center Boulevard • Sarasota, FL 34240 PHONE: 941/861-6133 • FAX: 941/526-1535 FloridaHealth.gov

